

MUSKOGEE County, Oklahoma
COUNTY PURCHASING OFFICE
 400 W BROADWAY, SUITE 110
 MUSKOGEE, OKLAHOMA 74401
 Phone Number (918) 682-2169

Invitation to Bid

PLEASE REVIEW TERMS AND CONDITIONS ON REVERSE SIDE
 RELATING TO SUBMISSION OF THIS BID.
 Notarized Affidavit completions and signature required on reverse side.

Date Issued May 15, 2023
 Page 1 of 4

BID NUMBER 68 **BID CLOSING DATE AND HOUR** 06/05/2023 9:30am **REQUIRED DELIVERY DATE**

(Days after award of Purchase Order) **Date of Delivery**

TERMS

| ITEM | QUANTITY | UNIT OF ISSUE | DESCRIPTION | UNIT PRICE | TOTAL |
|------|----------|---------------|--|------------|-------|
| | | | Webbers Falls Volunteer Fire Department is now accepting bids for a Compressor. Spec are attached. #68 MUST be on the outside of the envelope. Mail to: Muskogee County Clerk PO Box 1008 Muskogee, OK 74402 or Muskogee County Clerk 400 W Broadway Muskogee, OK 74401 If you have any questions, please feel free to contact: Polly Irving, Muskogee County Clerk 918-682-2169 or Dalton Armstrong, Webbers Falls Fire Chief 918-616-5741 | | |

TERMS and CONDITIONS

1. Sealed bids will be opened in the Commissioner's Conference Room, 400 W BROADWAY, SUITE 010
MUSKOGEE, Oklahoma, at the time and date shown on the invitation to bid form.
2. Late bids will not be considered. Bids must be received in sealed envelopes (one to an envelope) with bid number and closing date written on the outside of the envelope.
3. Unit prices will be guaranteed correct by the bidder.
4. Firm prices will be F.O.B. destination.
5. Purchases by MUSKOGEE County, Oklahoma, are not subject to state or federal taxes.
6. This bid is submitted as a legal offer and any bid when accepted by the County constitutes a firm contract.
7. Oklahoma laws require each bidder submitting a bid to a county for goods or services to furnish a notarized sworn statement of non-collusion. A form is supplied below.
8. Bids will be firm until 06/05/2023 (Date) 9:30am

AFFIDAVIT: I, the undersigned, of lawful age, being first duly sworn on oath say the he (she) is the agent authorized by the bidder to submit the above bid. Affiant further states that the bidder has not been a party to any collusion among bidders in restraint of freedom of competition by agreement to bid at a fixed price or to refrain from bidding; or with any state official or employee as to quantity; quality or price in the prospective contract or any other terms of said prospective contract; or in any discussions between bidders and any state official concerning exchange of money or other thing of value for special consideration in the letting of a contract; that the bidder/contractor has not paid, given or donated or agreed to pay, give or donate to any officer or employee of the State of Oklahoma (or other entity) any money or other thing of value, either directly or indirectly in the procuring of the award of a contract pursuant to this bid.

Subscribed and sworn before this _____ day

of _____, 20____ (SEAL)

Firm: _____

My commission expires _____ Signed by: _____
(Manual Signature of Undersigned)

Address: _____ Phone: _____

NOTARY PUBLIC (CLERK OR JUDGE) Zip: _____

In accordance with 62 O.S. § 310.9

NOTE: Other terms and conditions can be added at the discretion of the county officers.

The Webbers falls fire department is seeking bids from qualified vendors licensed to conduct business in the State of Oklahoma for a fully operational Compressed breathing air compressor , cascade and SCBA fill / containment system.

Specifications as follows:

1. Turnkey complete 6000 psi compressor with purification and all operating components capable of producing 16 cfm or more and capable of producing class A breathing air.
2. a 4 bottle ASME cascade system rated for 6000 psi.
3. A fill station containment system capable of holding at least 2 SCBA & or SCUBA tanks for refilling purposes.
4. All costs associated with the bid will be included in the bid quote. Examples are shipping delivery, installation, & air quality testing and certification by a third-party laboratory.
5. compressor motor is to be 10hp or larger single-phase electric
6. compressor is to be bult specifically for breathing air applications and can be new or used

. Contact person for this project is: Dalton armstrong 918-616-5741 darm192@gmail.com All equipment will meet applicable NFPA, ASTM, OSHA, & Dept of labor standards for breathing air systems in effect at the time of delivery.